

# Central Pump & Motor, LLC

4467 E. 50th Street  
 Suite 600  
 Des Moines, IA 50317  
 lisa@centralpumpiowa.com  
 515-412-1738

# Estimate

Date	Estimate #
5/6/2026	Q2561
Project	

## Name / Address

City of Bloomfield  
 111 West Franklin St  
 Bloomfield, IA 52537

Description	Qty	Rate	Total
Please review the following estimate for the repair of a Flygt 3153.181-0997, SN 0640052, 454 impeller, 20hp, 3ph, 230v, 1755rpm. Seal failure, stator burnt, possibly due to voltage issues. Location: Unknown			
Basic repair kit	1	1,828.24	1,828.24
6419305 Stator	1	3,695.00	3,695.00
7919900 FLS 10	1	479.91	479.91
6505100 Cable unit	1	167.91	167.91
Shop Labor - PS	9	150.00	1,350.00
Oil, Transformer Fee		65.00	65.00
Subtotal			7,586.06
Miscellaneous, supplies		1.00%	75.86
Repair only. Shipping is not included.			
		<b>Total</b>	<b>\$7,661.92</b>