

----- Forwarded message -----

From: **Richard Wilcox** <richard.wilcox@cityofbloomfield.org>

Date: Tue, Jul 6, 2021 at 2:42 PM

Subject: Sewer Plant Punch List Items.

To: Tomi Jo Day <tomiyo.day@cityofbloomfield.org>, Wildman, Matt <mwildman@hrgreen.com>, Jeremy Walker <jeremy.walker@cityofbloomfield.org>

I have listed some punch list items to H R Green Engineer -Matt Wildman, some of these Items may be resolved quickly, others may take some time. This is a normal part of any project.

Item 1. drainage ditch on the north side of the north access road.

2. Pipe in lagoon #2 has floated to top
3. Effluent wheel valve is loose in the sample structure
4. Control gage in new electric room has been bad for some time - flashing
5. Air cond in electrical room has tripped out . Need to verify the correct refrigerant charge.
6. Conduit not correct at splitter box.
7. Down spouts off of the Shop needs reconnected.
8. Condensate from the office unit is draining into the block wall.
9. Site drainage is referred to on page C111 of Signed BID SET dated 1/17/2020.
10. Blower Building Elevations are drawn on Page A201 of Signed BID SET dated 1/17/202
11. Blower Building East and West Elevations are on Page A202 of Signed BID SET dated 1/17/2020.
12. Photos of water infiltration are included in another email

--

Thank you! Rich Wilcox 641-208-6119